

**17.16.040: FIRE HYDRANTS:**

All subdivisions shall have fire hydrants installed at locations approved by the city after being reviewed by the fire chief and city engineer. No hydrant shall be placed more distant than five hundred feet (500') from the next closest hydrant. Also, a fire hydrant shall be placed within two hundred fifty feet (250') of each building lot, as measured within the public right of way. (Ord. 2002-04, 3-20-2002)