

15.08.05 Drinking Water Source Protection Ordinance

10. General Stormwater Management. All future stormwater management systems to be constructed and implemented for facilities within the protection zones and recharge areas shall be permitted in accordance with applicable local, state, and federal laws and regulations.

The discharge of stormwater into drainage wells or open sinkholes shall be prohibited without some form of treatment. This treatment shall be applied to at least the first 0.5-inch of runoff from the area tributary to the well or open sinkhole.

The Clean Water and Stormwater Regulations require municipalities and industries to identify, monitor, and limit urban runoff that may enter rivers, thus potentially affecting groundwater quality.