

15.08.05 Drinking Water Source Protection Ordinance

8. Septic Tank Systems. No person shall place, maintain, or operate onsite sewage disposal from a septic tank within the primary recharge area, Zone 1, Zone 2, or within 300 feet of any public street in which a public sewer is laid. Septic systems in Zones 3 and 4 shall comply with the Utah State Department of Health Care of Waste Disposal Regulations, Part IV and Part V.

Non residential activities which have septic tank systems shall have installed a 4-inch-diameter vertical pipe with a locked cap or locked top in the top of the septic tank. This monitoring pipe shall be located in a manner which will permit ready access by Department personnel to extract representative samples to check for improper/unauthorized disposal of regulated substances.

A septic holding tank that does not discharge into the soil would be preferred. The contents of a septic holding tank are removed, and can be treated or disposed of at an appropriate facility.