

15.08.05 Drinking Water Source Protection Ordinance

9. Sewage Collection, Transmission and Disposal. No person shall discharge treated or untreated sewage in any area not specifically designated for that purpose by the Department. The owner or operators of any wastewater treatment plant, sanitary sewer, force main, gravity sewer, or lateral shall notify the Department within 24 hours of discovering a break that may or does result in the leakage of sewage. Emergency telephone numbers will be prominently displayed on all sewage lift stations within Zones 1, 2, 3, and 4, and the primary recharging area.

All leaking sewage collection and transmission pipes shall be repaired or replaced. New sewage collection and transmission pipes shall be installed according to acceptable construction standards and shall have routine inspections during and after construction.

No person shall place, maintain, or operate a wastewater treatment plant within Zones 1 or 2.