

[Chapter 15.04 SUBDIVISIONS](#)

Section 15.04.550 Pipe laying.

All pipe installation shall proceed upgrade on a stable foundation with joints closely and accurately fitted.

Pipe shall be installed with uniform bearing under the full length, with a groove excavated in the bottom of the trench to receive the bottom quadrant of the pipe.

If adjustment of position of a pipe length is required after being laid, it shall be removed and rejoined as for a new pipe. When laying is not in progress, the ends of the pipe shall be closed with a tight-fitting stopper to prevent the entrance of foreign material.

In addition to the above requirements, all pipe installation shall comply with the specific requirements of the pipe manufacturer. (Ord. 5-1988 § 1 (part): Development Code 4-3-4)