

[Chapter 15.04 SUBDIVISIONS](#)

Section 15.04.770 Reinforcement and embedded items.

Reinforcing steel shall be clean and free from rust, scale, paint, grease or other foreign matter which might impair the bond. It shall be accurately bent and shall be tied to prevent displacement when concrete is poured. Reinforcing steel shall be held in place by only metal or concrete ties, braces and supports. No steel shall extend from or be visible on any finished surface.

The contractor shall use concrete chairs for holding the steel away from the subgrade, and spreader or other type bars for securing the steel in place. The spreader bars shall be not less than three-eighth inch in diameter. (Ord. 5-1988 § 1 (part): Development Code 4-6-6)