

[Chapter 15.04 SUBDIVISIONS](#)

Section 15.04.940 Gravel surface.

Where trenches are excavated through gravel-surfaced areas such as roads and shoulders, parking areas, unpaved driveways, etc. the gravel surface shall be restored and maintained as follows:

A. The gravel shall be placed deep enough to provide a minimum of six inches of material.

B. The gravel shall be placed in the trench at the time it is backfilled. The surface shall be maintained by blading, sprinkling, rolling, adding gravel, etc., to maintain a safe, uniform surface satisfactory to the County Surveyor. Excess material shall be removed from the premises immediately.

C. Material for use on gravel surfaces shall be obtained from sound, tough, durable gravel or rock meeting the following requirements for grading:

Passing 1-inch sieve	100 percent
Passing 1/2 -inch sieve	79-91 percent
Passing No. 4 sieve	49-61 percent
Passing No. 16 sieve	27-35 percent
Passing No. 200 sieve	7-11 percent.

(Ord. 5-1988 § 1 (part): Development Code 4-8-2)