

8. Fire Protection

Every dwelling within a manufactured home community shall be located no further than 500 feet from a fire hydrant.